



We help ideas meet the real world

Attestation of Conformity

No. 2012-050

Transmission performance of Data communication cable, Category 6

Company

MULTIMEDIA CONNECT TKH Group
Siège social et usine
8, rue de Biches
74100 Ville la Grand
France

Product description

Screened cable (F/UTP) characterised up to 250 MHz
Horizontal floor wiring cable, 100 Ω
4 twisted pairs with overall foil screen
PE jacket

Product identification

CX4PE

Generic cabling and cabling components standards - Category 6 cable requirements

- ISO/IEC 11801:2011 (Ed. 2.2)
- IEC 61156-5:2009 (Ed. 2.0)
- EN 50173-1:2011
- EN 50173-2:2007 including amendment A1:2010
- EN 50288-5-1:2003
- ANSI/TIA-568-C.2:2009

Technical report

DELTA-T201733-02, DANAK-19/11728

EC Cabling product ID

5498

Certificate valid until

1 August 2013

This product has been tested by EC Cabling Group of DELTA and complies with the transmission performance requirements of the above specified standards and "Terms and conditions for use of the EC VERIFIED marking on generic cabling products", DQP231006. The product takes part in a maintenance of certification schedule, which implies that EC Cabling performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis.

Hørsholm, 30 January 2012

Erik Bech
Test Manager

Claude Videt
Project Manager

DELTA

Venlighedsvej 4
2970 Hørsholm
Denmark

Tel. +45 72 19 40 00
Fax +45 72 19 40 01
www.madebydelta.com/cable



DANAK
TEST Reg. no. 19